

Example^a

EPA

287

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR Part 63 Subpart ZZZZ

REC'D
AUG 06 2010
APCO

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 2211

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: Lake Park Municipal Utilities

Facility name (if different): _____

Facility (physical location) address: 305 South Market Street
Lake Park, Iowa 51347

My facility is a (please choose one): ☐ Major source ☒ Area source
☐ Synthetic minor

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

^b Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Example^a

Owner name/title: Lake Park Municipal Utilities

Owner/company address: 217 Market Street P O Box 536

Lake Park, Iowa 51347

Owner telephone number: 712-832-3004

Owner email address (if available): Admin @ Lake Park Ia. Com

If the Operator information is different from the Owner, please provide the following:

Operator name/title: Lane Sether

Operator telephone number: 712-320-3178

Operator email address (if available): lpmu Lane @ mchsi.com

I hereby certify that the information presented herein is correct to the best of my knowledge.


(Signature)

8-4-10
(Date)

Lane Sether Electric Superintendent
(Name/title)

(712) 320-3178
(Telephone No.)



IOWA DEPARTMENT OF NATURAL RESOURCES
AIR QUALITY BUREAU

Initial Notification for Compression Ignition Engines^a

NESHAP for Reciprocating Internal Combustion Engines
40 Code of Federal Regulations (CFR) 63.6580 – 63.6675 (Subpart ZZZZ)

REC'D

Facility Information

AUG 06 2010

Name of Firm/Company:	Facility Name (if different):	Facility Number (if known):	
Lake Park Municipal Utilities			
Equipment Location - Street:	City:	State:	Zip:
305 South Market Street	Lake Park	Iowa	51347
Mailing Address (if different):	City:	State:	Zip:
Person to Contact:	Phone number:	Email (if available):	
Lane Sether	712-320-3178	lpmu.lane@mchsi.com	

This facility is a (please choose one):

- ☐ Major source: potential or actual emissions greater than 10 tons of any single hazardous air pollutant (HAP) or 25 tons of a combination of HAP
- ☒ Area source: potential and actual emissions below major source levels

Identification of Standard

- ☒ Yes, this facility is subject to 40 CFR Part 63, Subpart ZZZZ, *National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines* (RICE NESHAP):

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification requirement of 40 CFR 63, Subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

Engine Data

Emission Unit Number	web site IDNA Emission Unit Description	Is this an emergency engine?	Construction Date	Engine Model Year	Brake Horsepower (bhp)
EU 001	Generator	no	5/15/2004	20V4000-663L	3310
EU 002	Generator	no	5/15/2004	20V4000-6-63L	3310


Existing units: Initial notifications are required to be submitted by August 31, 2010 for the following:

- Area sources: Non-emergency engines > 300 bhp, installed before June 12, 2006
- Major sources: Non-emergency engines > 500 bhp, installed before December 19, 2002, and
Non-emergency engines > 100 and ≤ 500 bhp, installed before June 12, 2006

New units: Initial notifications are required to be submitted within 120 days of startup for the following:

- Major sources: All engines > 500 bhp installed on or after December 19, 2002

Signature

Responsible Official Certification		
<input checked="" type="checkbox"/>	I certify the truth, accuracy, and completeness of this notification.	
Responsible Official Name	Responsible Official Signature	Date
Lane Sether		8-3-2010

Submit this notification to the following agencies:

- ✕ ■ Director, Air and Waste Management Division, U.S. Environmental Protection Agency, 901 N. 5th Street, Kansas City, KS 66101
- ✕ ■ NESHA Coordinator, Iowa Department of Natural Resources, 7900 Hickman, Suite 1; Windsor Heights, IA, 50324
- If the facility is located in either Linn County or Polk County, this notification shall also be submitted to the appropriate county office:

Polk County Public Works – Air Quality Division
5885 NE 14th Street; Des Moines, IA 50313

Linn County Public Health - Air Quality Division
501 13th Street NW; Cedar Rapids, IA 52405